DUCTILE IRON FLANGED PIPE



Most commonly used in rigid pipe systems in well supported above ground pipe installations. Ductile iron Flanged pipe is particularly suited for water filtration plants, sewage disposal plants, wastewater treatment plants, pumping and lift stations, and industrial process plant applications.



The use of flanged joints in underground applications is generally not recommended. Piping should be properly anchored, supported,

and restrained to prevent damage to flanges. Flanged faces should bear uniformily on the gasket. Bolts should be tightened in a progressively criss-crossed pattern, such as tightening the bottom remaining bolts in a similar fashion. This criss-cross pattern should be repeated until the appropriate torque is applied. Care should be taken NOT to overtighten the bolts. Overtightening the bolts or attempting to close excess "gaps" between flanges will cause damage to the flange and pipe.



DUCTILE IRON FLANGED PIPE

- Ductile Iron Flanged Pipe is manufactured in accordance ANSI/AWWA C115/A21.15 See attached TABLE 1 for technical data.
- Ductile iron pipe conforms to ANSI/AWWA C151/A21.51. Pipe shall be minimum Class 53. C&B uses ductile iron pipe made in the USA.



A Flanges are made of ductile iron and are drilled in accordance with ANSI B16.1 CL 125 rated for 250 psi. ANSI CL 250 drilled flanges are available upon request. Flanges submitted are noted below. See attached TABLE 2 for technical data.



Flanges are manufactured from import sources. As an option to the customer, USA manufactured flanges may be selected. Flanges submitted are manufactured from IMPORT USA

- C&B wall collars are industry standard and are made of ductile iron (ASTM A536**n** 70:50:05) and are welded continously both sides of the collar with NI-55 weld rod. The collars are rated for 250 psi thrust load. See DI WALL PIPE submittal for technical data.
- C&B standard lining is double thickness cement mortar and bituminous seal coat in accordance with ANSI/AWWA C104/A21.4 C&B offers special linings when



PROTECTO 401 CBGL911 GLASS

- C&B standard exterior coating is bituminous asphalt in accordance with ANSI/AWWA C151/A21.51. If the pipe is required to be shop coated for temporary jobsite protection, refer to the included C&B Piping Coating Submittal attached.

30"-64" Flanged Pipe fabricated by C&B Piping, Inc will be furnished with FLANGE-TYTE Gaskets. This gasket is uniquely designed to perform best for use with ductile iron flanges.

If purchased from C&B, we can furnish 4"-24" FLANGE-TYTE Gaskets with your order at additional cost.

Approximate Bolt Torque (ft-lb)

	04"	06"	08"	10"	12"	14"	16"	18"	20"	24"	30"	36"	42"	48"	54"	60"	64"
150 P SI>															550	600	600
250 P SI>	90	90	90	90	90	110	110	120	120	130	140	160	585	625	5		
350 P SI>	110	110 1	10 130	130	150	160	180	200	220								



FLANGED PIPE



			MIN WALL	WEIGHT IN POUNDS						
(IN.)	PRESSURE RATING PSI	OUTSIDE DIAM. (IN.)	THICKNESS (CL53) (IN)	MAX LENGTH (FT-IN)	FLANGE	W/O FLGS PER/FT	WITH FLGS PER/EA			
03"	250	3.96	0.31	17' 6"	7	10.9	205			
04"	250 	4.80	0.32	19' 6"	13	13.8	295			
06"	250 	6.90	0.34	19' 6"	17	21.4	451			
08"	250 	9.05	0.36	19' 6"	28	30.1	643			
10"	250 	11.10	0.38	19' 6"	38	39.2	840			
12"	250 	13.20	0.40	19' 6"	58	49.2	1075			
14"	250 	15.30	0.42	19' 6"	72	60.1	1316			
16"	250 	17.40	0.43	19' 6"	80	70.1	1527			
18"	250 	19.50	0.44	19' 6"	90	80.6	1752			
20"	250 	21.60	0.45	19' 6"	115	91.5	2014			
24"	250 i	25.80	0.47	19' 6"	160	114.4	2551			
30"	250	32.00	0.51	17' 6"	240	154.4	3182			
36"	250	38.30	0.58	17' 6"	350	210.3	4380			
42"	250	44.50	0.65	17' 6"	500	274.0	5795			
48"	250	50.80	0.72	19' 0"	625	346.6	7835			
54"	250	57.56	0.81	19' 0"	670	441.9	9736			
60"	250	61.61	0.83 	19' 0"	1035	485.0	11285			
64"	250	65.67	0.87 	19' 0"	1510	542.0	13318			

TABLE 1

I This size may be rated at 350 psi if FLANGE-TYTE gaskets are utilized during installation.

Wall thickness corresponds to CL350 or 60" and 64" diameters

THREADED COMPANION FLANGE



SIZE (IN.)	OD	BC	т	BOLT DIA & LENGTH	# BOLTS
03"	7.50	6.00	0.75 ± .12	5/8 X 2 1/2	4
04"	9.00	7.50	0.94 ± .12	5/8 X 3	8
06"	11.00	9.50	1.00 ± .12	3/4 x 3 1/2	8
08"	13.50	11.75	1.12 ± .12	3/4 x 3 1/2	8
10"	16.00	14.25	1.19 ± .12	7/8 x 4	12
12"	19.00	17.00	1.25 ± .12	7/8 x 4	12
14"	21.00	18.75	1.38 ± .19	1 x 4 1/2	12
16"	23.50	21.25	1.44 ± .19	1 x 4 1/2	16
18"	25.00	22.75	1.56 ± .19	1 1/8 x 5	16
20"	27.50	25.00	1.69 ± .19	1 1/8 x 5	20
24"	32.00	29.50	1.88 ± .19	1 1/4 x 5 1/2	20
30"	38.75	36.00	2.12 ± .25	1 1/4 x 6 1/2	28
36"	46.00	42.75	2.38 ± .25	1 1/2 x 7	32
42"	53.00	49.50	2.62 ± .25	1 1/2 x 7 1/2	36
48"	59.50	56.00	2.75 ± .25	1 1/2 x 8	44
54"	66.25	62.75	3.00 ± .25	1 3/4 x 8 1/2	44
60"	73.00	69.25	3.12 ± .25	1 3/4 x 9	52
64"	80.00	76.00	3.38 ± .25	1 3/4 x 9	52

TABLE 2

Flanges are plain faces without projection or raised face and are furnished smooth or with shallow serrations.

 $\hfill\square$ $\hfill Flanges$ may be back or spot faced for compliance with flange thickness tolerances.

Pipe face-to-face dimensions conform to a tolerance of ±0.12 in. for FLG x FLG, ±0.25 in for FLG X PE.
Some spools may be available at "exact" length if specified in advance. Additional charges will apply

The bolt circle and bolt holes match those of ANSI/AWWA C115/A21.15 and CL125 flanges shown in ANSI B16.1. These flanges do not match the CL250 flange shown in ANSI B16.1 and cannot be joined with CL250 B16.1 fittings.



FLANGED PIPE MIN LENGTHS









FLANGE - FLANGE

FLANGE - PLAIN END (TR or HP)

MJ - FLANGE

TR FLEX - FLANGE

SIZE	F-F	F-PE	F-TRP	TMJ-FLG		тм	J-TMJ	TR BELL-F		
(IN.)	OA	OA	OA	OA	LL	OA	LL	OA	LL	
03"	4.25	2.75	х	6.50	4.00	9.00	4.00	х	Х	
04"	4.50	3.00	10.50	6.50	4.00	9.00	4.00	10.25	5.50	
06"	5.00	3.25	11.50	7.00	4.50	9.50	4.50	11.00	5.75	
08"	5.50	3.50	12.50	7.50	5.00	10.00	5.00	12.00	6.25	
10"	5.75	3.75	13.00	7.75	5.25	10.25	5.25	12.25	6.25	
12"	5.75	3.75	13.75	8.25	5.75	10.75	5.75	12.75	6.50	
14"	5.75	3.75	15.50	9.75	6.25	13.50	6.50	15.00	7.25	
16"	5.75	3.75	15.75	10.00	6.50	14.00	7.00	15.00	7.00	
18"	6.00	3.75	16.50	10.25	6.75	14.50	7.50	15.25	7.00	
20"	6.25	4.00	17.00	10.75	7.25	15.00	8.00	15.75	7.50	
24"	6.75	4.25	18.00	11.25	7.75	15.50	8.50	16.25	7.50	
30"	8.50	5.00	20.75	13.75	9.75	18.75	10.75	18.50	8.25	
36"	9.50	5.50	22.50	14.75	10.75	20.00	12.00	19.75	9.00	
42"	10.50	6.00	20.25	15.75	11.75	21.00	13.00	19.75	10.25	
48"	10.75	6.25	21.00	16.00	12.00	21.00	13.00	20.25	12.25	
54"	12.00	6.75	20.75	х	х	х	х	21.50	12.75	
60"	12.50	7.00	22.50	х	х	х	х	21.75	11.75	
64"	13.00	7.25	23.25	Х	х	х	х	23.00	12.50	

TABLE 3

For additional configurations not shown, please contact C&B Piping, Inc.
For RGRV x RGRV pipe, the min length for 3" & 4" is 4" OA, and 6"-36" is 0' 6" OA